



**District Level Water Analysis Laboratory Uttar Pradesh Jal
Nigam , Rural , Hapur (205101)
Test Report**



TC-12418

Test Report No.	UPJN/HPU/580	Issue Date	28/04/2026
Letter Number	19449/SKAGIC/2026-27	Location of Testing	Laboratory District Lab Hapur
Customer's Name	Smt.Kamla Agarwal Girls Inter College		
Address	Free Ganj Road, Hapur, 245101		

Sampling Method : UPJN(R)QSP/02/2.9

Sample Description – Drinking Water

Basic Details of Sample

Quantity of Sample	1 Lit.	Sample ID	UPJN/HPU/580
Condition of Sample	Plastic Bottle (at Room Temp)	Location of Sampling	Smt.Kamla Agar Girls Inter College
Type of Source	R.O.Water		
District	HAPUR	Block	HAPUR
Gram Panchayat	-	Village	-
Sampling Date	26/04/2026	Sampling Done By	Mr.Yogesh Tomer
Analysis Start Date	27/04/2026	Analysis Completion Date	27/04/2026
Temperature: 25±2 °C			Relative Humidity 50±15%

Technical Data of Analysis

S. No.	Test parameters	Unit of Measurement	Observed Value	Specific requirements as per IS 10500		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	pH at 25°C	-	6.20	6.5-8.5	6.5-8.5	IS 3025 (Part II): 2022
2	Turbidity	NTU	0.39	1	5	IS 3025 (Part 10): 2023
3	Total Dissolved Solids	mg/L	67	500	2000	IS 3025 (Part 16): 2023
4	Chloride (as Cl)	mg/L	34	250	1000	IS 3025 (Part 32): 2019
5	Total alkalinity (as CaCO ₃)	mg/L	84	200	600	IS 3025 (Part 23): 2023
6	Total hardness (as CaCO ₃)	mg/L	72	200	600	IS 3025 (Part 21): 2019
7	Calcium (as Ca)	mg/L	16	75	200	IS 3025 (Part 40): 2023
8	Magnesium (as Mg)	mg/L	7.76	30	100	IS 3025 (Part 46): 2023

1. This Test Report only to the particular sample(s) submitted for Analysis.
2. This Test Report shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained
3. The test results reported in this Test Report are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 07days (in case of non-perishable items only) from the date of issue of tests reports unless otherwise specified.
5. Water Sample is not Collected by us.

Prepared by

S.T. Kanhar
Authorized Signatory

(S.T. Kanhar)

Format No: HPU 7.8.2/1 (Rev. 1)



End of Test Report